S102S01/S102S02 S202S01/S202S02

SIP Type SSR for Medium Power Control

■ Features

1. High radiation resin mold package
2. RMS ON-state current
   I_T : 8 Arms at T_C <= 80˚C
   (With heat sink)
3. Built-in zero-cross circuit
   (S102S02/S202S02)
4. High repetitive peak OFF-state voltage
   S102S01/S102S02 V_{DRM}: MIN. 400V
   S202S01/S202S02 V_{DRM}: MIN. 600V
5. Isolation voltage between input and output
   (V_{iso}: 4 000V_{rms})
6. Approved by CSA, No. LR63705
   Recognized by UL, file No. E94758

■ Applications

1. Automatic vending machines, programmable controllers
2. Amusement equipment

■ Model Line-ups

	For 100V lines	For 200V lines
For phase control No built-in zero-cross circuit	**S102S01**	**S202S01**
Built-in zero-cross circuit	**S102S02**	**S202S02**

■ Outline Dimensions (Unit : mm)



■ Absolute Maximum Ratings (Ta = 25˚C)

Parameter		Symbol	Rating S102S01 S102S02	Rating S202S01 S202S02	Unit
Input	Forward current	I_F	50		mA
	Reverse voltage	V_R	6		V
Output	*1RMS ON-state current	I_T	8		A_{rms}
	*2Peak one cycle surge current	I_{surge}	80		A
	Repetitive peak OFF-state voltage	V_{DRM}	400	600	V
	Non-repetitive peak OFF-state voltage	V_{DSM}	400	600	V
	Critical rate of rise of ON-state current	dI/dt	50		A/μ s
	Operating frequency	f	45 to 65		Hz
*3Isolation voltage		V_{iso}	4 000		V_{rms}
Operating temperature		T_{opr}	- 25 to + 100		˚C
Storage temperature		T_{stg}	- 30 to + 125		˚C
*4Soldering temperature		T_{sol}	260		˚C

*1 T_C <=80˚C
*2 50Hz sine wave, T_j = 25˚C start
*3 60Hz AC for 1 minute, 40 to 60% RH, Apply voltages between input and output, by the dielectric withstand voltage tester with zero-cross circuit.
(Input and output shall be shorted respectively).
(Note)
When the isolation voltage is necessary at using external heat sink, please use the insulation sheet.
*4 For 10 seconds

■ Electro-optical Characteristics

(Ta = 25˚C)

Parameter			Symbol	Conditions	MIN.	TYP.	MAX.	Unit
Input	Forward voltage		V_F	I_F = 20mA	-	1.2	1.4	V
	Reverse current		I_R	V_R = 3V	-	-	10^{-4}	A
Output	Repetitive peak OFF-state current		I_{DRM}	$V_D = V_{DRM}$	-	-	10^{-4}	A
	ON-state voltage		V_T	Resistance load I_F= 20mA, I_T= 2Arms	-	-	1.5	V_{rms}
	Holding current		I_H	-	-	-	50	mA
	Critical rate of rise of OFF-state voltage		dV/dt	V_D = 2/3 • V_{DRM}	30	-	-	V/μs
	Critical rate of rise of commutating OFF-state voltage		$(dV/dt)_C$	T_j = 125˚C, dI_T/dt= - 4.0A/ms, V_D = 400V	5	-	-	V/μs
	Zero-cross voltage	S102S02 S202S02	V_{OX}	I_F = 8mA	-	-	35	V
Transfer characteristics	Minimum trigger current	S102S01 S202S01	I_{FT}	V_D = 12V, R_L = 30Ω	-	-	8	mA
		S102S02 S202S02		V_D = 6V, R_L = 30Ω	-	-	8	mA
	Isolation resistance		R_{ISO}	DC500V, 40 to 60 % RH	10^{10}	-	-	Ω
	Turn-on time	S102S01 S202S01	t_{on}	AC 50Hz	-	-	1	ms
		S102S02 S202S02			-	-	10	ms
	Turn-off time		t_{off}	-	-	-	10	ms
Thermal resistance (Between junction and case)			$R_{th(j-c)}$	-	-	4.5	-	˚C/W
Thermal resistance (Between junction and ambience)			$R_{th(j-a)}$	-	-	40	-	˚C/W

Fig. 1 RMS ON-state Current vs. Ambient Temperature



(1) With infinite heat sink
(2) With heat sink (200 x 200 x 2 mm Al plate)
(3) With heat sink (100 x 100 x 2 mm Al plate)
(4) With heat sink (75 x 75 x 2 mm Al plate)
(5) With heat sink (50 x 50 x 2 mm Al plate)
(6) Without heat sink
(Note) With the Al heat sink set up vertically,tighten the device at the center of the Al heat sink with a torque of 0.4N • m and apply thermal conductive silicone grease on the heat sink mounting plate. Forcible cooling shall not be carried out.

Fig. 2 RMS ON-state Current vs. Case Temperature



Fig. 3 Forward Current vs. Ambient Temperature



Fig. 4 Forward Current vs. Forward Voltage



Fig. 5 Surge Current vs. Power-on Cycle



Fig. 6 Maximum ON-state Power Dissipation vs. RMS ON-state Current (Typical Value)



Fig. 7 Minimum Trigger Current vs. Ambient Temperature (Typical Value)



Fig. 8 Repetitive Peak OFF-state Current vs. Ambient Temperature (Typical Value)



● Please refer to the chapter "Precautions for Use"

NOTICE

- The circuit application examples in this publication are provided to explain representative applications of SHARP devices and are not intended to guarantee any circuit design or license any intellectual property rights. SHARP takes no responsibility for any problems related to any intellectual property right of a third party resulting from the use of SHARP's devices.
- Contact SHARP in order to obtain the latest device specification sheets before using any SHARP device. SHARP reserves the right to make changes in the specifications, characteristics, data, materials, structure, and other contents described herein at any time without notice in order to improve design or reliability. Manufacturing locations are also subject to change without notice.
- Observe the following points when using any devices in this publication. SHARP takes no responsibility for damage caused by improper use of the devices which does not meet the conditions and absolute maximum ratings to be used specified in the relevant specification sheet nor meet the following conditions:

(i) The devices in this publication are designed for use in general electronic equipment designs such as:
— Personal computers
— Office automation equipment
— Telecommunication equipment [terminal]
— Test and measurement equipment
— Industrial control
— Audio visual equipment
— Consumer electronics

(ii) Measures such as fail-safe function and redundant design should be taken to ensure reliability and safety when SHARP devices are used for or in connection with equipment that requires higher reliability such as:
— Transportation control and safety equipment (i.e., aircraft, trains, automobiles, etc.)
— Traffic signals
— Gas leakage sensor breakers
— Alarm equipment
— Various safety devices, etc.

(iii) SHARP devices shall not be used for or in connection with equipment that requires an extremely high level of reliability and safety such as:
— Space applications
— Telecommunication equipment [trunk lines]
— Nuclear power control equipment
— Medical and other life support equipment (e.g., scuba).

- Contact a SHARP representative in advance when intending to use SHARP devices for any "specific" applications other than those recommended by SHARP or when it is unclear which category mentioned above controls the intended use.
- If the SHARP devices listed in this publication fall within the scope of strategic products described in the Foreign Exchange and Foreign Trade Control Law of Japan, it is necessary to obtain approval to export such SHARP devices.
-
- Contact and consult with a SHARP representative if there are any questions about the contents of this publication.