

C. Westbury 6-26-92
APPROVED BY/DATE

SAFETY ORGANIZATION(S).

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET.

- UL 544
- CSA 22.2, NO. 0.0.4, 8
- VDE 565-3

OPERATING SPECIFICATIONS.

- LINE VOLTAGE/CURRENT, 3 AMP., 120/250 VAC
- LINE FREQUENCY, 3 AMP./40°C, 250 VAC
- MAX. CASE RISE & RATED CURRENT, 50-60Hz
- MAX. LEAKAGE CURRENT, EACH 40°C
- LINE TO GROUND 2 μ A at 120V 60 Hz
- OPERATING AMBIENT TEMP. RANGE, 5 μ A at 250V 50 Hz
- IN AN AMBIENT, T_a , HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, I_o , IS AS FOLLOWS:

$$I_o = I_r \sqrt{\frac{85 - T_a}{45}}$$

RELIABILITY SPECIFICATIONS.

- STORAGE TEMPERATURE, -40°C TO +85°C
- HUMIDITY, 21 DAYS @ 40°C 95% RH
- CURRENT OVERLOAD TEST, 6 TIMES RATED CURRENT FOR 8 SECONDS

TEST SPECIFICATIONS.



- INDUCTANCE, 1.0 mH NOMINAL
- CAPACITANCE, (MEASURED @ 1 KHZ, 0.25 VAC MAX., 25°C $\pm$ 1°C)
- LINE TO LINE, .01 μ F $\pm$ 20%
- DISCHARGE RESISTOR, 1.5 Ma
- LINE/GROUND AND LINE/LINE 6000 Ma (MIN) AT 100 VDC
- INSULATION RESISTANCE 20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOUT.

- LINE TO GROUND, 2250 VDC FOR 1 MINUTE
- LINE TO LINE, 1450 VDC FOR 1 MINUTE

FILTER APPROVAL.

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



50a - 50a (MINIMUM) INSERTION LOSS									
FREQUENCY MHz	.15	.5	1	5	10	20	30		
COMMON dB	18	27	30	30	27	22	18		

This document is proprietary to CORCOM INC. and is not to be reproduced nor used for manufacturing purposes except on CORCOM's order or prior written consent.



LIBERTYVILLE, IL 60048

POWER LINE FILTER

AS SUPPLIED

AS SUPPLIED

FINISH:

AS SUPPLIED

DATE

NTS 9-12-89

REV. NO.

3EH1.01

*RESISTOR ADDED TO PRODUCT BUILT AFTER 3-30-92 (9212).