

UNISONIC TECHNOLOGIES CO., LTD

MBR3200 Preliminary DIODE

DO-201AD

SMC

(JEDEC DO-214AB)

SCHOTTKY BARRIER RECTIFIER

DESCRIPTION

The UTC MBR3200 is a schottky barrier rectifier, it uses UTC's advanced technology to provide customers with low forward voltage drop, high current capability and high efficiency, etc.

The UTC MBR3200 is suitable for free wheeling, high frequency inverters, low voltage and polarity protection applications.

FEATURES

- * Low forward voltage drop
- * High efficiency
- * Low power loss
- * High surge capability


SYMBOL




ORDERING INFORMATION

Ordering Number		Dookogo	Pin Assignment		Dooking	
Lead Free	Halogen Free	- Package	1	2	Packing	
MBR3200L-SMC-R	MBR3200G-SMC-R	SMC	K	Α	Tape Reel	
MBR3200L-Z21D-B	MBR3200G-Z21D-B	DO-201AD	K	Α	Tape Box	

Note: Pin Assignment: A: Anode K: Cathode



MARKING



www.unisonic.com.tw 1 of 3 QW-R202-020.b

ABSOLUTE MAXIMUM RATINGS

Ratings at 25°C ambient temperature unless otherwise specified.

Single phase, half wave, 60Hz, resistive or inductive load.

PARAMETER	SYMBOL	RATINGS	UNIT
DC Blocking Voltage	V_{RM}	200	V
RMS Reverse Voltage	$V_{R(RMS)}$	140	>
Maximum Recurrent Peak Reverse Voltage	V_{RRM}	200	>
Average Rectified Output Current	lo	3.0	Α
Non-Repetitive Peak Forward Surge Current: 8.3ms Single Half Sine-Wave Superimposed on Rated Load	I _{FSM}	80	Α
Operating Junction Temperature	TJ	-65~+150	°C
Storage Temperature	T _{STG}	-65~+150	°C

Note: Absolute maximum ratings are those values beyond which the device could be permanently damaged. Absolute maximum ratings are stress ratings only and functional device operation is not implied.

■ THERMAL DATA (Note 1)

PARAMETER		SYMBOL	RATINGS	UNIT	
Junction to Ambient	SMC	0	90	°C/W	
	DO-201AD	ÐJA	50	°C/W	

■ ELECTRICAL CHARACTERISTICS

PARAMETER	SYMBOL	TEST CONDITIONS	MIN	TYP	MAX	UNIT
Forward Voltage Drop (Note 2)	I V⊧	I _F =3.0A T _J =25°C			0.9	V
		I _F =3.0A, T _J =100°C			0.7	V
Peak Reverse Current at Rated DC		T _J =25°C			50	μΑ
Blocking Voltage	IR	T _J =100°C			10	mA

Notes: 1. Minimum Pad Area

2. Pulse test: 300µs pulse width, 1% duty cycle

UTC assumes no responsibility for equipment failures that result from using products at values that exceed, even momentarily, rated values (such as maximum ratings, operating condition ranges, or other parameters) listed in products specifications of any and all UTC products described or contained herein. UTC products are not designed for use in life support appliances, devices or systems where malfunction of these products can be reasonably expected to result in personal injury. Reproduction in whole or in part is prohibited without the prior written consent of the copyright owner. The information presented in this document does not form part of any quotation or contract, is believed to be accurate and reliable and may be changed without notice.

